





**Certificate:** 80160883

**Master Contract:** 201383

**Project:** 80160883

**Date Issued:** 10/03/2023

	220	60	2.5	3200
--	-----	----	-----	------

Notes:

1. All above models are rated for ambient temperature range in operation from -40°C to +60°C, 50% duty cycle and have operating characteristic of full travel from 0° to 90° (on/off).
2. These models have not been evaluated for safety applications or for use in hazardous locations.
3. A 10-amp fuse or circuit breaker shall be installed on the power supply wires for all SRX actuators. Failure to do so can cause operational failure and permanent damage to the actuators.



**Certificate:** 80160883

**Master Contract:** 201383

**Project:** 80160883

**Date Issued:** 10/03/2023

---

**APPLICABLE REQUIREMENTS**

CSA C22.2 No. 139-19 (Fifth Edition) - Electrically operated valves

UL 429 (Seventh Edition)(Reprint with revisions through and including March 19, 2021) - Electrically Operated Valves



**Certificate:** 80160883


**Project:** 80160883

**Master Contract:** 201383

**Date Issued:** 10/03/2023

**Notes:**

Products certified under Class C322102, C322152 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)





## *Supplement to Certificate of Compliance*

**Certificate:** 80160883

**Master Contract:** 201383

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80160883	October 03, 2023	Original Certification of SRX Actuator Series; Model SRX-0300, SRX-1200, SRX-1800 and SRX-3200.